LISTING SERVICE

LISTING No. 7300-1394:108   Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: *Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, P09 1JR, England
*Contact: Gordon Ash +44(0)23 9249 2412 FAX +44(0)23 9249 2754

DESIGN: *XP95A analog addressable signaling/contact monitoring modules. Model 55000-805 switch monitor module, Model 55000-806 priority switch monitor module, Model 55000-820 switch monitor input-output module, Model 55000-825 sounder control module, Model 55000-830 mini priority switch monitor module and Model 55000-831 mini switch monitor module. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: *Electrical: 17 to 28 VDC, 5 to 9 V protocol

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as monitoring modules for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

*Rev. 06-20-03KK

Date Issued: **JUNE 22, 2004**   *Listing Expires* **June 30, 2005**

Authorized By: **DIANE K. AREND**, *Senior Deputy Program Manager*